



NOTE:
 THE LOOPED LINE
 SHALL BE A MINIMUM 4"
 DIAMETER. LINES THAT
 SERVICE A FIRE HYDRANT
 SHALL BE A MINIMUM
 6" DIAMETER.

REVISION	BY	DATE	WATERLINE AT CUL-DE-SAC	
			STANDARD DETAILS	
			CITY OF COLLINSVILLE, OKLAHOMA	
			ENGINEERING DIVISION	
			DATE: 02/2020	STANDARD NO. WAT-11