



SECTION

- NOTES:
1. 3500 P.S.I. CONCRETE WITH NOT OVER 3" SLUMP.
 2. "W", "D", "T", AND "S" TO BE SHOWN ON THE PLAN.
 3. SEALED SAW CUT JOINTS @ 15' C/C.
 4. SEALED 3/4" EXPANSION JOINTS @ 90' C/C.
 5. TWO FEET (2') DEEP TOE WALL TO BE CONSTRUCTED AT EACH END.
 6. EXTEND REINFORCING STEEL INTO TOP WALL AND TOE WALL.
 7. WHERE REQUIRED ENERGY DISSIPATORS WILL BE CONSTRUCTED AS PART OF THE CHANNEL.

STANDARD DETAILS/STORM/STRM-14

REVISION	BY	DATE	CONCRETE SLOPE-WALL CHANNEL WITH UNDERDRAW STANDARD DETAILS	
			CITY OF COLLINSVILLE, OKLAHOMA	
			ENGINEERING DIVISION	
			DATE: 02/2020	STANDARD NO. STRM-14